

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221052
Address: 3206 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, August 24, 2023

Corrective Action Required:

1 Misc

- address pending driveway and sidewalk inspections
- pay all fees
- label all non GFCI outlets in unfinished areas
- outlet in pantry to be GFCI protected
- spark ring for outlet above fireplace
- safety glazing for basement windows less than 18" above floor
- spark ring for outlet in trim for mirror in master bath
- window fall protection in master bedroom where windows less than 24" from walking surface
- spark ring for outlet SW corner of master bedroom
- uncover covered manhole

Comments: