

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226048
Address: 160 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Curb Construction	Devon Perry	Passed	Thursday, August 24, 2023

Informational:
1 Misc 8-24-23 DP. Before pouring Curb they had aggregate compacted, they had epoxy coated steel for the bends of the curb and poured KCMMB 4k.

Comments: