

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226048  
Address: 160 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Devon Perry	Passed	Thursday, August 24, 2023

Informational:

1 Misc

8-24-23 DP. This area was not big enough for a proof roll. This spot was existing parking lot and the subgrade was still stable. They added AB3 and recompact before pouring concrete.

**Comments:**