

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231517  
Address: 500 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Alex Fischer	Not Ready	Friday, August 25, 2023

Partial Correction:

1	Misc	No complete inspection performed -revise and submit basement plans to show as built -provide I-joist and truss packets on site for inspection
---	------	---

Partial Correction:

2	Misc	NOT A COMPLETE LIST -Missing fire blocking at top plate north wall master bedroom
---	------	--

PROVIDE (COMPLETE) TRUSS PLANS  
AND I JOIST PLANS

RESUBMIT PLANS TO SHOW AS BUILT

**Comments:**