

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20224903  
Address: 2607 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, August 25, 2023

Corrective Action Required:

1 Misc

- outlet spacing in kitchen pantry counter top to comply with code section E3901.4.5
- guard rain required at basement steps
- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- address pending driveway inspection

**Comments:**