

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233098
Address: 1804 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Monday, August 28, 2023

Corrective Action Required:

1	Miscellaneous	-Gas line needs to be bonded
	Correction	-Gas line to fireplace is not connected or properly secured

Comments: