

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220580
Address: 3128 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Monday, August 28, 2023

Corrective Action Required:

1	Misc	-Erosion control failed -Sod not in place -Splash blocks not installed -Latch not working at sliding door -Spark rings are missing at tiled areas in kitchen -Missing all gutters and downspouts -Missing sump pump extension
---	------	---

Comments: