

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221052
Address: 3206 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Anthony Agcopra	Passed	Monday, August 28, 2023

Informational:

1 Misc

7-27-23 BR Sidewalk is framed and ready for concrete.

8-10-23 PS performed pre pour of Sidewalk on left (south side) of approach removed to repour to prevent valley for pooling of water on sidewalk.
Approved to pour sidewalk.

Comments: