



OFFICE: 6750 W. 47TH TERR.
MISSION, KANSAS 66203

Project: Saint Luke's East Hospital – Spect CT
Address: 100 NE Saint Luke's Blvd.

Response Letter Date: 8/16/2023

Reviewer – Fire Suppression Line Item # 1: Hydraulic Calculations missing from fire suppression submittal.

AMERICAN FIRE SPRINKLER CORPORATION - RESPONSE –Fire Suppression Line Item # 1: General Notes indicate system pipe shall be sized per existing system; new hydraulic calculations are not required.

Corey Scott
Designer
American Fire Sprinkler Corp.
6750 W. 47th Terr.
Mission, KS 66201

Tom Hampton
Professional Engineer
9400 Timber Meadows Dr.
Lee's Summit, Mo

