

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221806
Address: 3208 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, August 29, 2023

Corrective Action Required:

1 Misc

- garage door to be self closing and latching from a 45° angle
- window fall protection for windows in master bedroom
- 2 1/2" through bolts at each deck post to beam connection. Where over notched post use approved connectors
- uncover sewer tracer wire
- splash blocks missing on the north side of home
- obtain issued lawn irrigation permit

Comments: