



**LEE'S SUMMIT**  
MISSOURI



## **FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20230780	Date:	August 29, 2023
Project Title:	INTERNATIONAL TAP HOUSE - ITAP	Applicant:	
Location:			
228 SW MAIN ST, LEES SUMMIT, MO 64063		COLLINS WEBB ARCHITECTURE LLC	
Type of Work:		307 SW MARKET ST, Unit B	
Occupancy Group:	A-2	LEES SUMMIT, MO 64063	
Description:	CRAFT BEER/COCKTAIL BAR, FUTURE FOOD SERVICE AND PATIO SPACE	Primary: (816) 249-2270	
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Alarm Plan Review**

**Reviewed By: Jim Eden**

**Rejected**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide contractor shop drawings. Details on the notification appliances, and provide coverage to the complete space.

2. The drawings do not reflect existing conditions or provide adequate notification per NFPA 72. Revise and resubmit shop drawings.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**