

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233310

Address: 3745 SW CLAYTON PL, LEES SUMMIT, MO 640823743 SW CLAYTON PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Tuesday, August 29, 2023

Corrective Action Required:

1	Miscellaneous Correction	Full property erosion control is not in place. Erosion control must be maintained until occupancy
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	Full erosion control is still not in place. Erosion must be installed and maintained until full CO. Install erosion control and remove dirt and gravel from the streets. This includes the lots adjacent to this property. No inspections will be completed until proper erosion control is in place. 08/29/2023 KBEARD
---	--------------------------	--

Comments: