

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231716

Address: 2012 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822014 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822016 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822018 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Tuesday, August 29, 2023

Corrective Action Required:

1	Miscellaneous Correction	Full erosion control is missing, torn down or not installed and mud clods and gravel is in the street. Clean streets and install full erosion control. 08/16/2023. KBEARD
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	Full property erosion control is missing, torn down or never installed. Erosion control must be in place and maintained until full CO. Install perimeter erosion control and remove dirt and gravel from the streets. No inspections will be completed until full erosion control is in place. 08/29/2023 KBEARD
---	--------------------------	---

Comments: