

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233615

Address: 2140 SW OSAGE DR, LEES SUMMIT, MO 64082 2142 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Kyle Beard	Failed	Tuesday, August 29, 2023

Informational:

1	Miscellaneous Correction	Full erosion control is in place at the time of sewer inspection. Full erosion control must be in place until occupancy.
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	Erosion control has been knocked down and needs to be repaired or replaced. Full erosion control must be maintained until full CO. Remove all gravel and dirt from the street. No inspections will be completed until full erosion control is in place and maintained. 08/29/2023 KBEARD
---	--------------------------	---

**Comments:**