

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232458
Address: 2818 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Tuesday, August 29, 2023

Corrective Action Required:

1	Misc	-Fire approval required -Receptacle located within six ft of sink must be gfci-protected -Provide knee protection under sink -Provide backflow preventer for ice maker -Provide ADA compliant sale counter -Submit to city plan review egress through the electrical room but walls not demoed. Revised plan to include the relocation of plumbing fixture to break room wall
---	------	--

Comments: