

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231502  
Address: 2095 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, August 30, 2023

Informational:

1	Misc	-Nail portal frame top plate with 2 rows 16d sinkers 3" oc per detail -Pan off top of chase walls at hvac -Fireblock ceiling line at gathering room and second floor bathroom-SEAL GAPS -Sister studs over notched for bolts at rec room -Tighten anchor bolts in basement **OK TO INSULATE-DO NOT COVER INSPECTION ITEMS
---	------	--

**Comments:**