

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233098
Address: 1804 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Wednesday, August 30, 2023

Corrective Action Required:

1	Miscellaneous Correction	-Gas line to fireplace is not connected or properly secured
		Okay to insulate and sheetrock
		08/30/2023 KBEARD

Comments: