

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230813
Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Kyle Beard	Passed	Thursday, August 31, 2023

Informational:

1	Miscellaneous Correction	This is the footing for the monument sign. No drawing for the footing were included in the blue print. The on site superintendent had detailed notes from the engineer about the footing steel and the size of the concrete slab. There is underground electrical that is in the footing to be poured. Conduit measures 27 inches deep in the footing
---	--------------------------	---

Comments: