

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223020
Address: 2079 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Thursday, August 31, 2023

Corrective Action Required:

1	Misc	-seal top of meter can and A/C disconnect -missing splash blocks at exterior -missing water hammer device in laundry -missing spark rings at tiled areas in kitchen - label non GFCIs in garage -Need security screws on exterior door hinges per chapter 7 of city code
---	------	---

Comments: