

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220128  
Address: 102 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:   | Outcome: | Date:                     |
|---|--------------|----------|---------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Alex Fischer | Failed   | Thursday, August 31, 2023 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -address access to sconces at both sides of garage<br>-Need security screws on exterior door hinges per chapter 7 of city code<br>-label non GFCIs in garage<br>-missing fire blocking in basement behind furnace near duct to garage |
|---|------|---|

**Comments:**