

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222969
Address: 2067 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------------|--------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Alex Fischer | Failed | Friday, September 01, 2023 |

Corrective Action Required:

| | | |
|---|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -label non gfci's in garage -missing water hammer devices in laundry -Install junction box and approved appliance connector for hood -address light fixture too close to shelf in upstairs east bedroom closet -trim drain at egress window well at the back of the house -missing splash blocks |
|---|------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Comments: