

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20230107  
Address: 1501 NE US 40 HWY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Khanh Nguyen	Failed	Friday, September 01, 2023

Corrective Action Required:

1	Misc	-Min 12" cover of underground DVW pipes is required -Support pipe at maximum four ft interval -Provide 4" building drain as shown on plan. Submit revised as-built drawing of plumbing -Inspection of the sewer pipe to the grease trap is required
---	------	--

**Comments:**