

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, Unit:IR, LEES SUMMIT,
MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Failed	Friday, September 01, 2023

Corrective Action Required:

1 Misc

Misc pre final inspection:

****This is not a complete list:**

- Submit final 3rd party inspection report
- Complete all sight lighting, parking lot, door landings and egress paths
- Complete fire wall and rated assembly inspection
- Open all electrical panels for inspection
- Open all light pole hand holes for inspection
- Remove all furniture from tenant finish space
- Provide code compliant address on building

Comments: