CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20220490Address:2022 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: All Rough Inspection - Residential		Inspector: Mitchell Schwarz	Outcome: Failed	Date: Tuesday, September 05, 2023
1	Misc	Address missing anchor bolts on north garage wall. address joist in basement at garage door wall above furnace not landing or sill plate		
		Okay to insulate		

Comments: