

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232493  
Address: 618 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, September 05, 2023

Corrective Action Required:

1	Misc	-Provide panel schedule -Provide hammer arrestors at washing machine -Provide accessible restroom signage -Side wall grab bar to be max 12" from back wall and min 54" from back wall -Back wall grab bar to be max 6" from side and min 42" from side wall -Flush control to be on open side of toilet -Provide open faced toilet seat -Mirror to be max 40" aff to reflective surface -Latch at restroom door to be lever style
---	------	---

Comments: