

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232860
Address: 3217 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, September 05, 2023

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Fir out post garage- Fire block ends of soffit in garage- Unable to inspect deck roof, provide access- Unable to inspect framing of front porch, make accessible- Provide 1" clearance for B- vent in upstairs chase- Anchor double girder at bedroom 1 and Bvent, both must be anchored- Anchor steel columns in basement- Header cut joists at furnace- Correct erosion control- No pressure on gas line |
|---|------|---|

Comments: