

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192646
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Tuesday, September 05, 2023

Corrective Action Required:

1	Misc	**Exterior wall framing, columns and parapet ok to cover -In wall plumbing only ok at building 2 second floor restrooms 9/5/23 -COMPLETE ELECTRICAL AND SPRINKLER AT SOFFITS
---	------	--

Comments: