

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220067
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, September 06, 2023

Corrective Action Required:

1	Misc	-Shell needs to be completed before TI occupancy[-Provide accessible restroom signage -Missing cover plates in restroom -Open J box near drive through ceiling -Secure electrical at counter POS -Provide panel schedule -Move panel out to be flush with face of wall and deadfront -Obtain Jackson County Health Department approval -Complete all corrections for LSFD
---	------	--

Comments: