

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20224909

Address: 520 NE TOWN CENTRE DR, Unit:F, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line Construction Inspection</b>	Nick Scott	Partial	Tuesday, August 29, 2023

Informational:

1 Misc

Site visited to look at fire line that is connected to the building and the crews refused to pour a concrete kicker block and after a while they poured it and sent pictures.

**Comments:**