

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230780
Address: 228 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Thursday, September 07, 2023

Corrective Action Required:

1	Misc	Provide Health dept approval. Fire ok for TCO pending codes. Label mechanical room door" Electrical room" Post address over rear west entry and over southwest entry(pizza door side). Provide combustion air size and requirements for mechanical room.
---	------	---

Comments: