

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231814

Address: 500 NE TOWN CENTRE DR, LEES SUMMIT, MO 640642201 NE TOWN CENTRE BLVD, LEES SUMMIT,
MO 640642200 NE INDEPENDENCE AVE, LEES SUMMIT, MO 640642251 NE TOWN
CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Failed	Thursday, September 07, 2023

Informational:

1	Misc	-8" SS building drain at north side of building from west end to ~ line 12 is installed; L7.5/ from north CO through south wall
		-Floor drain line from PRZ rm to building drain; FD from sprinkler rm to bd

Corrective Action Required:

2	Misc	Pressure test of the underslab plumbing not holding
---	------	---

Comments: