

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233098  
Address: 1804 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Kyle Beard	Passed	Friday, September 08, 2023

Corrective Action Required:

1	Miscellaneous Correction	-Gas line to fireplace is not connected or properly secured
		Okay to insulate and sheetrock 08/30/2023 KBEARD

**Comments:**