

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231016
Address: 2075 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, September 08, 2023

Corrective Action Required:

1 Misc

- Nail overlapping joists per code
- Seal fireblocking at fur out wall in master bath
- Provide (2) nchor bolts at front basement bed plate break in middle 3rd of plate

OK to insulate

Comments: