

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20220522  
**Address:** 3522 SE CORBIN DR, LEES SUMMIT, MO 64082  
**Inspected On:** Friday, September 08, 2023  
**Inspected By:** Kyle Beard  
**Expiration Date:** 10/8/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Pending	
---	------------	---------	--

**Corrective Action Required:**

1	Misc	Sod to siding must be at least 6 inches in height. Sod must have a 2 percent slope away from the foundation. **MISSING SOD AT DECK NOT READY
---	------	---

**Corrective Action Required:**

2	Miscellaneous Correction	-Sod to siding must be at least 6 inches in height. Sod must have a 2 percent slope away from the foundation. -**MISSING SOD AT DECK NOT READY -Pay all fees associated with permit 08/08/2023 KBEARD
---	-----------------------------	--