## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20222785

Address: 1220 NW MAIN ST, Unit:IR, LEES SUMMIT, MO 640861220 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly Inspection Robb Popp Not Ready Friday, September 08,

2023

Corrective Action Required:

1 Misc -SCREW PATTERN AT RISER ROOM OK

\*\*SEAL AT PRECAST WALL BEAM POCKET, PERIMETER AND ALL PENETRATIONS

\*\*\*9/8/23 NOT READY

**Comments:**