

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214024
Address: 4729 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Friday, September 08, 2023

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	9-8-23 Site visit made. Storm gutter, street, and sidewalks are full of mud. These shall be cleaned ASAP. Damaged silt fence along the street shall be replaced
---	----------------------------	---

**Failure to correct erosion control deficiency within 2 days will result in issuance of a stop-work order

Comments: