

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221051
Address: 3218 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Anthony Agcopra	Partial	Monday, September 11, 2023

Informational:

1 Misc

7-27-23 BR Sidewalk is framed and ready for concrete.

9-5-23 A.A Sidewalk on south side of property is framed . Aggregate is compacted. Slopes are in compliance. Conditions can change, Approved to pour ,

9-11-23 A.A Conditions have not changed. Not poured yet

Comments: