

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, Unit:IR, LEES SUMMIT,  
MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line Construction Inspection</b>	John Jackson	Passed	Tuesday, September 12, 2023

Informational:

1 Misc

07/25/23 Tuesday JMJ ( Central Plumbing-Steve )

Fire lines and hydrants for building #1 were flushed to remove all possible obstruction from line.

09/12/23 Tuesday JMJ ( Central Plumbing-Steve )

Contractor painted fire hydrant red around building #1 except for painted hydrant near back flow vault on the Northeast side hydrant top was painted silver.

**Comments:**