

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225142
Address: 374 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Tuesday, September 12, 2023

Corrective Action Required:

1	Misc	-Missing exterior security flood lighting per chapter 7 of the city code at back of house -Front and back sconce lights not tamper resistant per chapter 7 of the city code -Remove all plastic covers from smoke alarms -Missing caulk at top of all exterior disconnects -Sod has not been installed
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: