

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232254

Address: 400 SW LONGVIEW BLVD, Unit:190, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Wednesday, September 13, 2023

Corrective Action Required:

1	Misc	- functional back exit
		- exit lighting at front entrance to function at time of power outage

Comments: