

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230813
Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Ryan Heckman	Partial	Friday, May 05, 2023

Informational:

1 Misc

5-5-23 RH. Aggregate base was placed on top of geogrid that was placed on the South East side of the parking lot.

8-10-23 PS Contractor placing and spreading aggregate at rear east side of buliding at dock area

9-13-23 BR Contractor placing 4" asphalt base (type 1) over compacted subgrade.

9-14-23 BR Contractor placing 2" asphalt surface (type 3) over asphalt base

Comments: