

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232451
Address: 2611 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, September 15, 2023

Corrective Action Required:

2 Misc

- anchor bolts in garage to be in the middle 1/3 of sill plate.
- remove/move trash and building materials to inspect all of garage
- address rafter landing on multiple blocks throughout
- address plumbing and electrical drilled closer than 2" above garage entry bathroom
- fire block garage wall to kitchen furr down
- complete plumbing for master bath shower
- address holes drilled closer than 2" to one another above master bed entry
- plans call for 3 king studs each side of front entry
- solid block sheathing seams bed 4 bath
- weld beam web stiffeners to plans and provide weld certificate on file

Comments: