



## Comment Response Letter

---

**Recipient:**

**Name:** Joe Frogge  
**Email:**  
**Phone:** 816.969.1241

**Address** Joe Frogge  
Plans Examiner  
Lee's Summit, MO

**Subject:** Code Comment Response Letter

**Sender:**

**Name:** Bo Osborn  
**Email:** bo.osborn@dialecticeng.com  
**Phone:** (816) 997-9575

**Permit #:** PRCOM20234141  
**Project Name:** Swig - Lee's Summit, MO

**Project #:** 10202383.02

**Date** September 13, 2023

---

**Comments:**

<u>Comment #</u>	<u>Sheet(s) Affected</u>	<u>Comment/Response</u>
4		<p>2018 IFC 1008.1 Illumination required. The means of egress, shall be illuminated at all times the building space served by the means of egress is occupied.</p> <p><b>Response:</b> <i>Emergency lighting provided via fixture OC-32 wall pack which is to be provided with 90-minute integral battery backup. Fixture description revised to clarify this and align with the indicated model number in Lighting Fixture Schedule.</i></p>
8		<p>Provide emergency lighting at exterior side of exit door.</p> <p><b>Response:</b> <i>Emergency lighting provided via fixture OC-32 wall pack which is to be provided with 90-minute integral battery backup. Fixture description revised to clarify this and align with the indicated model number in Lighting Fixture Schedule.</i></p>