

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225294
Address: 5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Friday, September 15, 2023

Corrective Action Required:

1	Misc	In-wall for 2nd fl only: -Protect water line at bottom wall track where within 1.25" of surface -Fb all floor penetrations -Complete all trades. Do not cover duct chases -Complete captain bathroom wall -Missing receptacle at captain bunk bed
---	------	--

****OK TO INSULATE**

Comments: