

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214955
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Monday, September 18, 2023

Corrective Action Required:

1	Misc	Inspection on HT101A, HT202 AND HT203 ONLY
		<ul style="list-style-type: none">- fire stop all penetrations in welding room- Upload information on the fire proofing on trusses in welding room- Provide engineers letter on ventilation for welding room.

OK to put in furniture in class rooms: HT101A, HT202, HT203

Corrective Action Required:

2	Misc	Paint shop
		<ul style="list-style-type: none">- open Jbox in second floor mechanical room- provide gas piping pressure certificate or set up test- secure electrical conduit at North East entrance

Comments: