

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224097
Address: 2767 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Anthony Agcopra	Passed	Monday, September 18, 2023

Informational:
1 Misc

5-22-23 DP. Crew had SW formed, aggregate compacted. Cross slopes were in compliance but conditions can change. Approved to pour.

9-18-23 A.A SW is poured. Slopes are in compliance . Frames are pulled .
Passed

Comments: