

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224097
Address: 2767 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Shawn Hoffman | Failed | Monday, September 18, 2023 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Provide screws for front door hinges- Provide Splash blocks- Seal top of electrical meter and a/c disconnect- Uncover manhole at North West corner of lot- Obtain an irrigation permit and submit a back flow certification |
|---|------|---|

Comments: