

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20223648  
Address: 2767 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Monday, September 18, 2023

Corrective Action Required:

1	Misc	-Provide label on no GFCI outlets throughout - Provide water hammer device at laundry - Provide slash blocks - Attach a/c whip 12" from disconnect - Seal top of electrical meter and a/c disconnect - Per chapter 7 security code, no lighting 8 foot or under to have open bulb access -
---	------	--

Comments: