

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

September 19, 2023

studio605
8604 Sagamore Rd
Leawood, KS 66206

Permit No: PRCOM20234451
Project Title: BABY BUMP IMAGING
Project Address: 1002 SW BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 61330168900000000
Location / Legal: RNG-31 TWP-47 SEC-06 PT SW 1/4 DAF: BEG AT A PT 1150' W OF SE COR SD SW 1/4 TH N 28'
Description: M/L TO N ROW LI OF 3RD ST & TRU POB TH CONT N 220' TH E 130' TO SW COR LOT 58 ROBIN
HILLS TH N 125' TO S ROW LI OF
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR ULTRASOUND CLINIC WITH COFFEE BAR

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the company name of the licensed general contractor and an email address & phone number for the on-site contact which is where inspection reports will be sent.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors. (Electrician required)

Building Plan Review

Reviewed By: Joe Frogge

Rejected

DEVELOPMENT SERVICES

1. 2018 IBC 1109.12.3 Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: Modify plan to show that countertop has at least 3 linear feet of space no taller than 36".

2. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 797-7162. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is informational.

3. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 797-7162. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is informational.

4. ICC A117.1 Section 404.2.3.2 Swinging Doors and gates. Swinging doors and gates shall have maneuvering clearances complying with Table 404.2.3.2.

Action required: Minimum 18" clearance required at latch side of door next to mop sink. i.e. 18" minimum between latch side of door and new wall.

5. 2018 IBC 1209.2 Finish Materials. Walls, Floors and partitions in toilet and bathrooms shall comply with Sections 209.2.1 through 1209.2.4.

2018 1209.2.1 Floors and wall bases. In other than dwelling units, toilet, bathing and shower room floor finish materials shall have a smooth, hard, nonabsorbent surface. The intersections of such floors with walls shall have a smooth, hard, nonabsorbent vertical base that extends upward onto the walls not less than 4 inches.

2018 1209.2.2 Walls and partitions. Walls and partitions within 2 feet of service sinks, urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of not less than 4 feet above the floor, and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. (See code section for possible exceptions.)

Action required: Specify compliant finish materials at mop sink (and RR if finishes are new) are compliant. If paint is used it must be epoxy based.

6. 2018 IPC 802.1 Where required. Food-handling equipment, in other than dwelling units, clear-water waste, humidifiers, dish-washing machines and utensils, pots, pans and dishwashing sinks shall discharge through an indirect waste pipe as specified in Sections 802.1.1 through 802.1.8. Fixtures not required to be indirectly connected by this section and the exception to Section 301.6 shall be directly connected to the plumbing system in accordance with Chapter 7.

Action required: Indirect drains required at 3-compartment sink and ice maker. Amend designs to demonstrate compliance. (floor sink may be required)

7. 2017 NEC Article 517.13 Grounding of Receptacles and Fixed Electrical Equipment in Patient Care Spaces. Wiring in patient care spaces shall comply with 517.13(A) and (B).

(A) Wiring methods. All branch circuits serving patient care spaces shall be provided with an effective ground-fault current

DEVELOPMENT SERVICES

path by installation in a metal raceway system, or a cable having a metallic armor or sheath assembly. The metal raceway system, metallic cable armor, or sheath assembly shall itself qualify as an equipment grounding conductor in accordance with 250.118.

(B) Insulated Equipment Grounding Conductors and Insulated Equipment Bonding Jumpers.

(1) General. The following shall be directly connected to an insulated copper equipment grounding conductor that is clearly identified along its entire length by green insulation and installed with the branch circuit conductors in the wiring methods as provided in 517.13(A).

1. The grounding terminals of all receptacles other than isolated ground receptacles.

2. Metal outlet boxes, metal device boxes, or metal enclosures.

3. All non-current-carrying conductive surfaces of fixed electrical equipment likely to become energized that are subject to personal contact, operating at over 100 volts. (see code for exceptions)

(2) Sizing. Equipment grounding conductors and equipment bonding jumpers shall be sized in accordance with 250.122.

Action required: Modify drawings to show that all circuits in imaging room will have redundant ground system.

Fire Plan Review

Reviewed By: Jim Eden

Approved with Conditions

1. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of one, 2A,10B,C fire extinguisher at a conspicuous location. Verified at inspection.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.