

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614
Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, September 19, 2023

Informational:	
1	Misc
	Foundation wall OK: -Elevator pit f. walls
	Footing OK below: -Elevator pad (per engineer letter) -From O/9 to M/27-OK pending confirmation from the engineer of the cross #5 rebar length

Comments: